



GOVERNMENT OF TELANGANA
FIRE, DISASTER RESPONSE, EMERGENCY & CIVIL DEFENCE DEPARTMENT
NO OBJECTION CERTIFICATE



From
 Director General,
 Fire, Disaster Response, Emergency & Civil Defence
 Department,
 Telangana, Hyderabad.

To,
 DRK INSTITUTE OF SCIENCE & TECHNOLOGY,
 SY NO. 460,462,464, AT BOWRAMPET,
 QUTHBULLAPUR MDL,
 HYDERABAD
 MEDCHAL MALKAJGIRI DIST,
 TELANGANA-500 043

Rc. No.560940002021 Dated:11/03/2021

Sir,
 Sub: Telangana Fire, Disaster Response, Emergency &
 Civil Defense Department –Label Issue of No Objection
 Certificate for **OCCUPANCY** to the Multi storeyed Building
 of DRK INSTITUTE OF SCIENCE & TECHNOLOGY, SY
 NO. 460,462,464, AT BOWRAMPET, QUTHBULLAPUR
 MDL, HYDERABAD, MEDCHAL MALKAJGIRI DIST,
 TELANGANA-500 043

Ref: 1. Acknowledgement No560940002021 dt.11/03/2021
 2. This Office Provisional NOC RC No.460530002020 dt.11/03/2021
 3. Inspection Committee Report, Hyderabad Rc. No. 560940002021, dt. 11/03/2021

1. The Multi Storeyed Building Inspection committee, vide reference cited (3) have inspected the Multi Storeyed Building of **DRK INSTITUTE OF SCIENCE & TECHNOLOGY, SY NO. 460,462,464, AT BOWRAMPET, QUTHBULLAPUR MDL, HYDERABAD, MEDCHAL MALKAJGIRI DIST, TELANGANA-500 043** and submitted the following report.

2. The builder was issued Provisional No Objection certificate vide reference cited (2) for construction of Multi Storeyed Building with **1 Ground + 5 FLOORS**, for Occupancy . Now the builder has constructed Multi Storeyed Building with **1 Ground + 5 FLOORS** , with a height of **11.00** Meters for **EDUCATIONAL BUILDINGS (G1+5 FLOORS) (Low Hazard)** Occupancy and requested for No Objection Certificate for Occupancy.

3. Open Spaces : The builder provided the following open spaces all around the building.

Sl.No	side	Open space Required as per Provisional No Objection Certificate	Open space provided
1	North	6.00	6.00
2	South	6.00	6.00
3	East	6.00	6.00
4	West	6.00	6.00
5	Front Direction		

4. Means of Access :

Sl. No	Gate Width As per NBC 2016	Required	Provided
1	Entry gate width	6.00	6
2	Entry Gate Head Clearance	4.50	5
3	Exit Gate Width	6.00	6
4	Exit Gate Head Clearance	4.50	5

Gupta
 PRINCIPAL

DRK Institute of Science & Technology
 Bowrampet, Quthbullapur,
 Hyderabad - 500 043,